


Example of useful **AHU Modbus ODS**



Black	Value/Status
Green	Setpoints/Command
Red	Alarm
Blue	Actual setpoint-value

ODS

Counter-flow heat exchanger

ST41	3x0036	Heat recovery output signal
ST42	3x0131	Heat recovery output signal defrost damper
ST43	3x0132	Heat recovery output signal defrost damper
GP8	3x0099	Act.pressure over Counterflow heat exchanger
GP21	3x0096	Exhaust air flow
GT31	3x0072	Outside air temperature
	3x0129	Defrost Active
	3x0126	Normal pressure calculated