


Example of useful **AHU BACnet BYP**



Black	Value/Status
Green	Setpoints/Command
Red	Alarm
Blue	Actual setpoint-value

BYP

Plate heat
exchanger

ST4	5922	Heat recovery output signal
GM1	37799	Room humidity relative (%)
GT4:1	33725	Cold corner
GT4:2	40895	Extract air temperature